



170008222878 (2020)国认监认字(347)号



中国认可
国际互认
检测
TESTING
CNAS L1020



实验室名称：国家电器产品质量监督检验中心

Lab Name: China National Center for Quality Supervision
and Test of Electrical Apparatus Products

No 21K1406-S

第一册 Part One

检验（试验）报告

Test Report

委托单位：西藏华东水电设备成套有限公司

Client:

产品名称：户内高压交流固封式真空断路器

Name of Product:

产品型号：VS1-12/1250-31.5

Product Type:

检验类别：型式试验

Test Category:



本实验室对出具的检验（试验）结果负责，未经实验室书面同意，不得部分地复制本报告。

The laboratory is responsible for the inspection (Test) results. The report shall not be reproduced except in full, written approval of the laboratory.



170008222878 (2020)国认监认字(347)号



中国认可
国际互认
检测
TESTING
CNAS L1020



实验室名称：国家电器产品质量监督检验中心

Lab Name: China National Center for Quality Supervision
and Test of Electrical Apparatus Products

No 21K1406-S

第二册 Part Two

检验（试验）报告

Test Report

委托单位：西藏华东水电设备成套有限公司

Client:

产品名称：户内高压交流固封式真空断路器

Name of Product:

产品型号：VS1-12/1250-31.5

Product Type:

检验类别：型式试验

Test Category:



本实验室对出具的检验（试验）结果负责，未经实验室书面同意，不得部分地复制本报告。

The laboratory is responsible for the inspection (Test) results. The report shall not be reproduced except in full, written approval of the laboratory.

国家电器产品质量监督
检验中心

检 验 报 告

VS1-12/1250-31.5
户内高压交流固封式真空断路器

检 验 结 论

实施的检 验项目及 检验结果	电缆充电电流开合试验 (C2 级) [CC1 12kV 2.5~10A 24 次 "O"]	合格
	[CC2 12kV >25A 24 次 "CO"]	合格
	三相电容器组 (单个) 电流开合试验 (C2 级) [BC1: 12kV 63A~252A 24 次 "O"]	合格
	[BC2: 12kV ≥630A 80 次 "CO"]	合格
	三相电容器组 (背对背) 电流开合试验 (C2 级) [BC1: 12kV 40A~160A 24 次 "O"]	合格
	[BC2: 12kV >400A 80 次 "CO"]	合格
依据标准	GB/T 1984-2014 《高压交流断路器》	
	GB/T11022-2011 《高压开关设备和控制设备标准的共用技术要求》	
检验结论	经过对西藏华东水电设备成套有限公司生产的 VS1-12/1250-31.5 户内高压交流固封式真空断路器进行了型式试验检验, 检验结果符合上述依据标准及产品技术文件的规定, 检验结果合格。 注: 本结论仅对送试样品负责。	
编制: 袁佳玉	校对: 刘俊强	审核: 陈恩
日期: 2021-04-15	日期: 2021-04-15	日期: 2021-04-15
		批准: 康
		日期: 2021-04-15